

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548262	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.07Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548263	Centrifuge	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.30Ohm Pass	>200MOhm Pass		0.19mA Pass
Business Name	Head Office	548264	Oven	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.26Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548265	Oven	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.30Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548266	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.07Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548267	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.07Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548268	Oven	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.24Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548269	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548270	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.07Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548271	Computer	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.19Ohm Pass			0.21mA Pass
Business Name	Head Office	548272	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.20Ohm Pass			0.19mA Pass
Business Name	Head Office	548273	Sample Fridge	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.59Ohm Pass			0.13mA Pass
Business Name	Head Office	548274	Sample Fridge	Fail	Matt H	15/09/2025	15/09/2026	Lab	Fail	1.19Ohm Fail			
Business Name	Head Office	548275	Sample Fridge	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.19Ohm Pass			0.13mA Pass
Business Name	Head Office	548276	3P Compressor	Pass	Matt H	15/09/2025	30/12/2023	Lab	Pass	0.93Ohm Pass	>200MOhm Pass		1.45mA Pass
Business Name	Head Office	548277	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.11Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548278	Balancer	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.11Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548279	Test Unit	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.11Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548280	Micro Saw	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass		>200MOhm Pass		
Business Name	Head Office	548281	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass		>200MOhm Pass		
Business Name	Head Office	548282	Compressor	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.11Ohm Pass	>200MOhm Pass		0.13mA Pass
Business Name	Head Office	548283	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.16Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548284	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.16Ohm Pass	>200MOhm Pass	OK Pass	

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548285	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass		>200MOhm Pass		
Business Name	Head Office	548287	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.160hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548288	IEC Lead	Fail	Matt H	15/09/2025	15/09/2026	Lab	Fail				
Business Name	Head Office	548289	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.150hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548290	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.100hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548291	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.150hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548292	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.200hm Pass			0.14mA Pass
Business Name	Head Office	548293	Computer	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.230hm Pass			0.16mA Pass
Business Name	Head Office	548294	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.380hm Pass			0.14mA Pass
Business Name	Head Office	548295	Computer	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.340hm Pass			0.16mA Pass
Business Name	Head Office	548296	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.140hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548297	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.130hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548298	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.120hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548299	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.130hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548300	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.120hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548301	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.120hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548302	Oil Pump	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.200hm Pass	>200MOhm Pass		
Business Name	Head Office	548304	Water Analyser	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.190hm Pass	>200MOhm Pass		
Business Name	Head Office	548305	3P Compressor	Pass	Matt H	15/09/2025	15/09/2026	Lab	Pass	0.190hm Pass			0.32mA Pass
Business Name	Head Office	548382	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.270hm Pass			0.17mA Pass
Business Name	Head Office	548383	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.270hm Pass			0.17mA Pass
Business Name	Head Office	548384	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.480hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548385	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.460hm Pass	>200MOhm Pass	OK Pass	

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548386	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.45Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548387	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.08Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548388	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.08Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548389	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.08Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548390	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.08Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548391	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.08Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548392	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548393	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548394	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.54Ohm Pass			0.15mA Pass
Business Name	Head Office	548395	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.46Ohm Pass			0.15mA Pass
Business Name	Head Office	548396	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.47Ohm Pass			0.15mA Pass
Business Name	Head Office	548397	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.16Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548398	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.16Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548399	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548400	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.07Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548401	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.07Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548402	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.04Ohm Pass			0.14mA Pass
Business Name	Head Office	548403	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.56Ohm Pass			0.14mA Pass
Business Name	Head Office	548404	USB Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548405	Speaker	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548406	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548407	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548408	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	

In-Service Safety Inspection and Test Report - AS/NZS 3760

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548409	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548410	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548411	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.28Ohm Pass			0.17mA Pass
Business Name	Head Office	548412	Printer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.33Ohm Pass			0.17mA Pass
Business Name	Head Office	548413	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548414	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548415	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.12Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548416	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.98Ohm Pass			0.26mA Pass
Business Name	Head Office	548417	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.45Ohm Pass			0.26mA Pass
Business Name	Head Office	548418	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548419	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548420	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.50Ohm Pass			0.17mA Pass
Business Name	Head Office	548421	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.43Ohm Pass			0.17mA Pass
Business Name	Head Office	548422	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.23Ohm Pass			0.17mA Pass
Business Name	Head Office	548423	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548424	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548425	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548426	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548427	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548428	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548429	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.27Ohm Pass			0.24mA Pass
Business Name	Head Office	548430	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.24Ohm Pass			0.23mA Pass
Business Name	Head Office	548431	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548432	Printer Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548433	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548434	Printer Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548435	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548436	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548437	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.56Ohm Pass			0.41mA Pass
Business Name	Head Office	548438	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.11Ohm Pass			0.41mA Pass
Business Name	Head Office	548439	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548440	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548441	Printer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548442	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548443	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548444	Dymo Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548445	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548446	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548447	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548448	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.05Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548449	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.08Ohm Pass			0.17mA Pass
Business Name	Head Office	548450	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.23Ohm Pass			0.17mA Pass
Business Name	Head Office	548451	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.37Ohm Pass			0.17mA Pass
Business Name	Head Office	548452	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548453	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548454	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.06Ohm Pass	>200MOhm Pass	OK Pass	

In-Service Safety Inspection and Test Report - AS/NZS 3760

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548455	Fridge	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.460hm Pass			0.03mA Pass
Business Name	Head Office	548456	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.050hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548457	Intermec Unit	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.050hm Pass	>200MOhm Pass		
Business Name	Head Office	548458	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548459	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.050hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548460	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.050hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548461	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.060hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548462	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.050hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548463	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.050hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548464	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.100hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548465	Monitor Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548466	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.650hm Pass			0.45mA Pass
Business Name	Head Office	548467	Computer	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass	0.500hm Pass			0.46mA Pass
Business Name	Head Office	548469	Vacuum Supply	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548470	Radio	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548471	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Main Office	Pass		>200MOhm Pass		
Business Name	Head Office	548491	Phone Supply	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass		>200MOhm Pass		
Business Name	Head Office	548492	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.420hm Pass			0.17mA Pass
Business Name	Head Office	548493	Computer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.080hm Pass			0.17mA Pass
Business Name	Head Office	548494	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.150hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548495	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.140hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548496	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.140hm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548497	IEC Lead	Fail	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.140hm Pass	>200MOhm Pass	LN Cross Fail	

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548498	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.41Ohm Pass			0.13mA Pass
Business Name	Head Office	548499	Computer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.100Ohm Pass			0.17mA Pass
Business Name	Head Office	548500	Printer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.090Ohm Pass			0.12mA Pass
Business Name	Head Office	548501	Printer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.230Ohm Pass			0.21mA Pass
Business Name	Head Office	548502	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass		>200MOhm Pass		
Business Name	Head Office	548503	Printer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass		>200MOhm Pass		0.21mA Pass
Business Name	Head Office	548504	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass		>200MOhm Pass		
Business Name	Head Office	548505	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.140Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548506	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.140Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548507	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.150Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548508	Coffee Machine	Pass	Matt H	15/09/2025	30/12/2023	Back of House	Pass		>200MOhm Pass		
Business Name	Head Office	548509	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.220Ohm Pass			0.17mA Pass
Business Name	Head Office	548510	Computer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.240Ohm Pass			0.17mA Pass
Business Name	Head Office	548511	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.110Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548512	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.090Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548513	Microscope	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.100Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548514	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.090Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548515	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.090Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548516	Power Board	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.090Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548517	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.240Ohm Pass			0.17mA Pass
Business Name	Head Office	548518	Computer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.240Ohm Pass			0.17mA Pass
Business Name	Head Office	548519	Figure 8 Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass		>200MOhm Pass		
Business Name	Head Office	548520	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.120Ohm Pass	>200MOhm Pass	OK Pass	

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548521	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.11Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548522	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.11Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548525	Computer	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.26Ohm Pass			0.17mA Pass
Business Name	Head Office	548526	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass		>200MOhm Pass		
Business Name	Head Office	548528	Magnifying Lamp	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.21Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548529	Microscope	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.22Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548530	Microscope	Pass	Matt H	15/09/2025	15/09/2026	Back of House	Pass	0.26Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548531	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.11Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548532	Fridge	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.11Ohm Pass			0.08mA Pass
Business Name	Head Office	548533	Fridge	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.10Ohm Pass			0.07mA Pass
Business Name	Head Office	548534	Iron	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.11Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548535	Scale Supply	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass		>200MOhm Pass		
Business Name	Head Office	548536	Scale Supply	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass		>200MOhm Pass		
Business Name	Head Office	548537	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.10Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548538	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.10Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548539	Heat Press	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.10Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548540	Heat Press	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.10Ohm Pass	>200MOhm Pass		
Business Name	Head Office	548541	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass		>200MOhm Pass		
Business Name	Head Office	548542	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass		>200MOhm Pass		
Business Name	Head Office	548543	Power Supply	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass		>200MOhm Pass		
Business Name	Head Office	548544	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.11Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548545	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.11Ohm Pass	>200MOhm Pass	OK Pass	
Business Name	Head Office	548546	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.12Ohm Pass	>200MOhm Pass	OK Pass	

Number of single phase items tested: 195

Number of three phase items tested: 5

Number of portable RCDs tested: 0

Project	Building	Asset ID	Asset Description	Status	User	Test Date	Retest Date	Site	Visual Test	Earth Continuity	Insulation	Polarity Test	Dif. Leakage
Business Name	Head Office	548547	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.820hm Pass			0.17mA Pass
Business Name	Head Office	548548	Computer	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.840hm Pass			0.17mA Pass
Business Name	Head Office	548549	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.830hm Pass			0.17mA Pass
Business Name	Head Office	548550	Computer	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.850hm Pass			0.17mA Pass
Business Name	Head Office	548551	Microwave Oven	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.230hm Pass	>200M0hm Pass		
Business Name	Head Office	548552	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.110hm Pass	>200M0hm Pass	OK Pass	
Business Name	Head Office	548553	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.100hm Pass	>200M0hm Pass	OK Pass	
Business Name	Head Office	548554	Water Analyser	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.100hm Pass	>200M0hm Pass		
Business Name	Head Office	548555	Kettle	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.100hm Pass	>200M0hm Pass		
Business Name	Head Office	548556	Fridge	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.520hm Pass			0.17mA Pass
Business Name	Head Office	548574	Computer	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.670hm Pass			0.18mA Pass
Business Name	Head Office	548575	Printer	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.350hm Pass			0.18mA Pass
Business Name	Head Office	548576	Monitor	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.670hm Pass			0.18mA Pass
Business Name	Head Office	548577	IEC Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.140hm Pass	>200M0hm Pass	OK Pass	
Business Name	Head Office	548578	Heat Sealer	Fail	Matt H	15/09/2025	15/09/2026	Loading Dock	Fail				
Business Name	Head Office	548579	Extension Lead	Pass	Matt H	15/09/2025	15/09/2026	Loading Dock	Pass	0.120hm Pass	>200M0hm Pass	OK Pass	